

# Renovation & Expansion of Towers Hall Dormitory

Angelo Faia

**Christine Kerner** 

**Douglas Wentzel** 

John Braley BS AE - Structural

BS CE - Geotechnical

BS AE - Mechanical

BS AE - Structural

Advisor: Dr. Franklin Moon
Civil, Architectural and Environmental Engineering
College of Engineering



### **Problem Statement**

A survey of Towers Dormitory's interior and exterior revealed a building that provided poor living conditions and had aesthetics inconsistent with Drexel's Strategic plan. Analysis of the University's student population and projected growth over the next decade showed that there will be a dire need for additional student housing. Our goal was to design a solution to both of these problems.


Structural • Mechanical • Geotechnical








#### **Design Options**



## **Architectural Design**







	EXISTING	PROPOSED	INCREASE	
GROSS SF	127,000	260,000	105 %	
EXTERIOR FACE	360 LF	500 LF	40 %	
BEDS	624	1,085	74 %	
- POOMS				

BATHROOMS
AMENITIES
CIRCULATION
VERTICAL TRANSPORTATION
MECHANICAL SHAFTS

#### **Structural Design**







3D CAD model

SAP2000 analytical models with applied loads

Due to differential stiffness, the addition was observed to deform in a twisting motion about the existing building. Walls and beams were added and removed in an iterative process until the problem was remedied.

This twisting deformation causes a great deal of stress at the corners of a building and can result in damage as seen in the John Hancock Tower pictured at right.



Γ	60 ft	٦
[ 7	TO THE PERSON OF	9
Ľ	60 ft	1

A 5' thick mat foundation with 6ksi concrete was designed for the 19 story addition

## Mechanical Design



Senior Design 2013


Secondary systems will include active and passive chilled beam units with a radiant heating and cooling panel system in the atrium. Water chillers and steam supply will constitute the primary system.



TRACE 700 RESULTS	Sensible (Btu/hr)	Latent (Btu/hr)	Total (Btu/hr)	Delta (Btu/hr)	Reduction
Baseline Cooling Load ASHRAE Compliant:	4,055,000	1,550,000	5,605,000	1,180,000	21%
Proposed Cooling Load Sustainable Features:	3,000,000	1,425,000	4,425,000		21%



#### **Site Design**





## **Schedule & Budget**

